

**CABLE AND CONDUIT ENTRY DEVICES**

The cable and conduit entry devices and blanking elements shall be of a certified flameproof type EEx d, suitable for the conditions of use and correctly installed. With the use of conduit entries a sealing device shall be provided immediately on the entrance of the enclosure.

All cable glands and conduit fittings, including conduit plugs, must meet or exceed the area approval where unit is being installed.